Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2020-02-14-46 **Date: 25/11/2019**

: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

Reference : EE(Project)/Ynk Zone/WO/67/2019-20

: 20-11-19

: Drain SideWall Concrete

Size : 150X150X150 mm

Age : M20 / 7 Days Compressive Strength

BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 25/11/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Drain SideWall Concrete	M20	18/11/2019	25/11/2019	149.71 X 151.19 X 150.77	22634	**8.982**	415.4	18.4	18.3
Drain SideWall Concrete	M20	18/11/2019	25/11/2019	149.78 X 150.31 X 150.96	22513	**8.699**	415.2	18.4	
Drain SideWall Concrete	M20	18/11/2019	25/11/2019	150.44 X 149.02 X 150.87	22418	**8.679**	404.6	18.0	

Asst. Executive Engineer
15/12/20
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro
Sig.....
Date.....
BANGALORE

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2020-02-14-46 **Date: 16/12/2019**

: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

Reference : EE(Project)/Ynk Zone/WO/67/2019-20

: 20-11-19

: Drain SideWall Concrete

/Size : 150X150X150 mm

/Age : M20 / 28 Days Compressive Strength

BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 16/12/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Drain SideWall Concrete	M20	18/11/2019	16/12/2019	151.04 X 151.57 X 150.58	22893	8.944	548.7	24.0	23.2
Drain SideWall Concrete	M20	18/11/2019	16/12/2019	149.19 X 150.39 X 151.65	22436	8.448	504.9	22.5	
Drain SideWall Concrete	M20	18/11/2019	16/12/2019	151.58 X 150.84 X 149.99	22864	8.850	526.6	23.0	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2020-02-14-46 **Date: 26/11/2019**

: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

Reference : EE(Project)/Ynk Zone/WO/67/2019-20

: 21-11-19

: Drain SideWall Concrete

Type /Size : 150X150X150 mm

grade/Age : M20 / 7 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 26/11/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failu Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Drain SideWall Concrete	M20	19/11/2019	26/11/2019	151.94 X 151.89 X 151.54	23077	**8.982**	429.9	18.6	18.7
Drain SideWall Concrete	M20	19/11/2019	26/11/2019	151.26 X 150.27 X 149.13	22730	**8.699**	421.3	18.5	
Drain SideWall Concrete	M20	19/11/2019	26/11/2019	151.66 X 151.70 X 151.85	23007	**8.679**	437.1	19.0	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2020-02-14-46 **Date: 17/12/2019**

: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

Reference : EE(Project)/Ynk Zone/WO/67/2019-20

: 21-11-19

: Drain SideWall Concrete

Type/Size : 150X150X150 mm

Age : M20 / 28 Days Compressive Strength

BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 17/12/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Drain SideWall Concrete	M20	19/11/2019	17/12/2019	149.49 X 149.32 X 150.05	22321	8.944	523.4	23.4	23.1
Drain SideWall Concrete	M20	19/11/2019	17/12/2019	150.72 X 150.87 X 150.52	22739	8.448	504.6	22.2	
Drain SideWall Concrete	M20	19/11/2019	17/12/2019	149.93 X 151.77 X 149.54	22755	8.850	541.4	23.8	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO Sig..... Date..... BANGALORE

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2020-02-14-46 **Date: 26/11/2019**

:

Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

: EE(Project)/Ynk Zone/WO/67/2019-20

: 21-11-19

: Drain SideWall Concrete

: 150X150X150 mm

: M20 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 26/11/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Drain SideWall Concrete	M20	19/11/2019	26/11/2019	149.78 X 150.26 X 149.36	22506	8.982	408.2	18.1	18.3
Drain SideWall Concrete	M20	19/11/2019	26/11/2019	149.85 X 151.87 X 150.91	22757	8.699	410.0	18.0	
Drain SideWall Concrete	M20	19/11/2019	26/11/2019	150.83 X 149.93 X 149.93	22615	8.679	422.2	18.7	

AE
Asst Executive Engineer
Project Division
Yelahanka Zone

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO Sig..... Date..... BANGALORE

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2020-02-14-46 **Date: 17/12/2019**

: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

Reference : EE(Project)/Ynk Zone/WO/67/2019-20

: 21-11-19

ID : Drain SideWall Concrete

Type /Size : 150X150X150 mm

grade/Age : M20 / 28 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 17/12/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Drain SideWall Concrete	M20	19/11/2019	17/12/2019	151.96 X 150.54 X 150.47	22876	**8.944**	543.1	23.7	23.2
Drain SideWall Concrete	M20	19/11/2019	17/12/2019	149.44 X 149.76 X 151.63	22379	**8.448**	494.2	22.1	
Drain SideWall Concrete	M20	19/11/2019	17/12/2019	149.19 X 150.79 X 150.32	22496	**8.850**	536.6	23.9	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro BANGALORE
Sig.....
Date.....

****End of Report****

: 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2020-02-14-46 **Date: 26/11/2019**

: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

Reference : EE(Project)/Ynk Zone/WO/67/2019-20

Receipt : 21-11-19

ID : Drain SideWall Concrete

Type /Size : 150X150X150 mm

grade/Age : M20 / 7 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 26/11/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Drain SideWall Concrete	M20	19/11/2019	26/11/2019	150.55 X 150.88 X 150.21	22716	8.982	428.8	18.9	18.7
Drain SideWall Concrete	M20	19/11/2019	26/11/2019	150.96 X 150.54 X 151.00	22727	8.699	420.6	18.5	
Drain SideWall Concrete	M20	19/11/2019	26/11/2019	151.91 X 151.60 X 150.37	23029	8.679	432.3	18.8	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO Sig..... Date..... BANGALORE

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 17/12/2019

: CP-2020-02-14-46

: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

's Reference : EE(Project)/Ynk Zone/WO/67/2019-20

Receipt : 21-11-19

ID : Drain SideWall Concrete

Type /Size : 150X150X150 mm

grade/Age : M20 / 28 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Test : 17/12/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Drain SideWall Concrete	M20	19/11/2019	17/12/2019	149.92 X 149.41 X 151.43	22399	8.944	522.6	23.3	23.0
Drain SideWall Concrete	M20	19/11/2019	17/12/2019	151.14 X 150.76 X 151.26	22786	8.448	506.3	22.2	
Drain SideWall Concrete	M20	19/11/2019	17/12/2019	150.65 X 150.60 X 150.15	22688	8.850	535.2	23.6	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE
Sig.....
Date.....

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2020-02-14-46 **Date: 29/11/2019**

: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

's Reference : EE(Project)/Ynk Zone/WO/67/2019-20

Receipt : 25-11-19

ID : Drain Side Filling Concrete

Type /Size : 150X150X150 mm

grade/Age : M20 / 7 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Test : 29/11/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Drain Side Filling Concrete	M20	22/11/2019	29/11/2019	151.59 X 150.79 X 151.02	22857	**8.982**	420.3	18.4	18.3
Drain Side Filling Concrete	M20	22/11/2019	29/11/2019	151.66 X 150.40 X 151.19	22810	**8.699**	425.1	18.6	
Drain Side Filling Concrete	M20	22/11/2019	29/11/2019	150.54 X 150.21 X 149.51	22613	**8.679**	407.3	18.0	

Asst. Engineer
Project Director
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

	: CP-2020-02-14-46	Date: 20/12/2019
Name	: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.	
	: Executive Engineer KRIDL Bangalore	
's Reference	: EE(Project)/Ynk Zone/WO/67/2019-20	
Receipt	: 25-11-19	
ID	: Drain Side Filling Concrete	
Type /Size	: 150X150X150 mm	
grade/Age	: M20 / 28 Days Compressive Strength	
to BIS codes	: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5	
Test	: 20/12/2019	

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Drain Side Filling Concrete	M20	22/11/2019	20/12/2019	150.55 X 151.86 X 150.69	22862	8.944	543.5	23.8	23.0
Drain Side Filling Concrete	M20	22/11/2019	20/12/2019	151.75 X 149.87 X 149.31	22742	8.448	501.9	22.1	
Drain Side Filling Concrete	M20	22/11/2019	20/12/2019	149.86 X 150.88 X 151.21	22611	8.850	522.2	23.1	

Asst. Executive Engineer
Project Director
Vekhanic Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

: 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2020-02-14-46 **Date: 29/11/2019**

: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

Reference : EE(Project)/Ynk Zone/WO/67/2019-20

Receipt : 25-11-19

ID : Drain Side Filling Concrete

Type /Size : 150X150X150 mm

grade/Age : M20 / 7 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Test : 29/11/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Drain Side Filling Concrete	M20	22/11/2019	29/11/2019	150.93 X 151.53 X 149.57	22870	**8.982**	432.2	18.9	18.4
Drain Side Filling Concrete	M20	22/11/2019	29/11/2019	151.02 X 150.91 X 149.05	22790	**8.699**	417.6	18.3	
Drain Side Filling Concrete	M20	22/11/2019	29/11/2019	150.71 X 150.44 X 150.24	22673	**8.679**	409.0	18.0	

Asst. Executive Engineer
Project Director
Vetebantic Zone
Ranebure

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2020-02-14-46 **Date: 20/12/2019**

: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

Reference : EE(Project)/Ynk Zone/WO/67/2019-20

Receipt : 25-11-19

ID : Drain Side Filling Concrete

Type /Size : 150X150X150 mm

grade/Age : M20 / 28 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 20/12/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Drain Side Filling Concrete	M20	22/11/2019	20/12/2019	151.27 X 150.15 X 150.32	22713	8.944	534.3	23.5	23.5
Drain Side Filling Concrete	M20	22/11/2019	20/12/2019	150.15 X 149.31 X 151.31	22420	8.448	515.4	23.0	
Drain Side Filling Concrete	M20	22/11/2019	20/12/2019	150.78 X 150.75 X 150.10	22729	8.850	542.7	23.9	

Asst. E. 13/2/2020
Project Director
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2020-02-14-46 **Date: 03/12/2019**

: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

Reference : EE(Project)/Ynk Zone/WO/67/2019-20

Receipt : 28-11-19

ID : RMC

Type /Size : 150X150X150 mm

grade/Age : M20 / 7 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Test : 03/12/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
RMC	M20	26/11/2019	03/12/2019	149.49 X 150.75 X 151.24	22535	**8.113**	422.8	18.8	18.5
RMC	M20	26/11/2019	03/12/2019	149.56 X 151.18 X 151.17	22609	**8.868**	416.4	18.4	
RMC	M20	26/11/2019	03/12/2019	149.39 X 151.15 X 151.84	22581	**8.534**	415.5	18.4	

Asst. Engineer 15/12/2020
Project Zone
Bangalore

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2020-02-14-46** **Date: 24/12/2019**

: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

Reference : EE(Project)/Ynk Zone/WO/67/2019-20

Receipt : 28-11-19

ID : RMC

Type /Size : 150X150X150 mm

Grade/Age : M20 / 28 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Test : 24/12/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
RMC	M20	26/11/2019	24/12/2019	150.41 X 151.35 X 149.64	22764	**8.652**	546.1	24.0	23.4
RMC	M20	26/11/2019	24/12/2019	149.16 X 150.59 X 149.10	22462	**8.369**	505.9	22.5	
RMC	M20	26/11/2019	24/12/2019	151.35 X 149.59 X 150.46	22640	**8.046**	536.4	23.7	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2020-02-14-46 **Date: 03/12/2019**

: Improvements CC Roads and Darin at Kogilu Layout in Ward No.05 Byatarayanapura Sub Division.

: Executive Engineer KRIDL Bangalore

Reference : EE(Project)/Ynk Zone/WO/67/2019-20

Receipt : 28-11-19

ID : RMC

Type /Size : 150X150X150 mm

grade/Age : M20 / 7 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Test : 03/12/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
RMC	M20	26/11/2019	03/12/2019	151.06 X 150.10 X 149.69	22675	**8.113**	414.8	18.3	18.4
RMC	M20	26/11/2019	03/12/2019	149.88 X 151.18 X 151.69	22659	**8.868**	411.3	18.2	
RMC	M20	26/11/2019	03/12/2019	149.76 X 150.97 X 150.89	22609	**8.534**	426.6	18.9	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore
15/2/2019

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com